



- (NOTE 1) Insert FUSES according to the ENGINE requirements.
- (NOTE 2) The minium size shall be not less than 2.5sq mm.
- (NOTE 3) The sum of relay-current outputs may not exceed 4Adc
- (NOTE 4) Grounding of the C.Ts is mandatory
- (NOTE 5) Electric interlock is mandatory

[*] Suppress relays at source using flywell diodes or suppression devices